

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/249/25	Model No.: KFARQ-6-50%	Date: 24-07-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 249/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 24801 To 24900 And 24805A	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 24805A and removed from the Lot/Batch							
24801	Pass	24802	Pass	24803	Pass	24804	Pass
24805	Pass	24806	Pass	24807	Pass	24808	Pass
24809	Pass	24810	Pass	24811	Pass	24812	Pass
24813	Pass	24814	Pass	24815	Pass	24816	Pass
24817	Pass	24818	Pass	24819	Pass	24820	Pass
24821	Pass	24822	Pass	24823	Pass	24824	Pass
24825	Pass	24826	Pass	24827	Pass	24828	Pass
24829	Pass	24830	Pass	24831	Pass	24832	Pass
24833	Pass	24834	Pass	24835	Pass	24836	Pass
24837	Pass	24838	Pass	24839	Pass	24840	Pass
24841	Pass	24842	Pass	24843	Pass	24844	Pass
24845	Pass	24846	Pass	24847	Pass	24848	Pass
24849	Pass	24850	Pass	24851	Pass	24852	Pass
24853	Pass	24854	Pass	24855	Pass	24856	Pass
24857	Pass	24858	Pass	24859	Pass	24860	Pass
24861	Pass	24862	Pass	24863	Pass	24864	Pass
24865	Pass	24866	Pass	24867	Pass	24868	Pass
24869	Pass	24870	Pass	24871	Pass	24872	Pass
24873	Pass	24874	Pass	24875	Pass	24876	Pass
24877	Pass	24878	Pass	24879	Pass	24880	Pass
24881	Pass	24882	Pass	24883	Pass	24884	Pass
24885	Pass	24886	Pass	24887	Pass	24888	Pass
24889	Pass	24890	Pass	24891	Pass	24892	Pass
24893	Pass	24894	Pass	24895	Pass	24896	Pass
24897	Pass	24898	Pass	24899	Pass	24900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory