

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/A50/RQ/041/25	Model No.: KMPRQ-10-50%	Date: 20-09-2025
Type and Capacity of Extinguisher	: KMPRQ-10-50%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMPRQ50%10 041/25	
Batch Quantity	: 20.00 Nos.	
Serial Numbers	: 00801 To 820	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00801 To 820 and removed from the Lot/Batch							
801	Pass	802	Pass	803	Pass	804	Pass
805	Pass	806	Pass	807	Pass	808	Pass
809	Pass	810	Pass	811	Pass	812	Pass
813	Pass	814	Pass	815	Pass	816	Pass
817	Pass	818	Pass	819	Pass	820	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory