

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/313/25	Model No.: MARQ-6-50%	Date: 10-10-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 313/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 31201 To 31300 And 31205A	
Month of Manufacturing	: Oct/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 31205A and removed from the Lot/Batch							
31201	Pass	31202	Pass	31203	Pass	31204	Pass
31205	Pass	31206	Pass	31207	Pass	31208	Pass
31209	Pass	31210	Pass	31211	Pass	31212	Pass
31213	Pass	31214	Pass	31215	Pass	31216	Pass
31217	Pass	31218	Pass	31219	Pass	31220	Pass
31221	Pass	31222	Pass	31223	Pass	31224	Pass
31225	Pass	31226	Pass	31227	Pass	31228	Pass
31229	Pass	31230	Pass	31231	Pass	31232	Pass
31233	Pass	31234	Pass	31235	Pass	31236	Pass
31237	Pass	31238	Pass	31239	Pass	31240	Pass
31241	Pass	31242	Pass	31243	Pass	31244	Pass
31245	Pass	31246	Pass	31247	Pass	31248	Pass
31249	Pass	31250	Pass	31251	Pass	31252	Pass
31253	Pass	31254	Pass	31255	Pass	31256	Pass
31257	Pass	31258	Pass	31259	Pass	31260	Pass
31261	Pass	31262	Pass	31263	Pass	31264	Pass
31265	Pass	31266	Pass	31267	Pass	31268	Pass
31269	Pass	31270	Pass	31271	Pass	31272	Pass
31273	Pass	31274	Pass	31275	Pass	31276	Pass
31277	Pass	31278	Pass	31279	Pass	31280	Pass
31281	Pass	31282	Pass	31283	Pass	31284	Pass
31285	Pass	31286	Pass	31287	Pass	31288	Pass
31289	Pass	31290	Pass	31291	Pass	31292	Pass
31293	Pass	31294	Pass	31295	Pass	31296	Pass
31297	Pass	31298	Pass	31299	Pass	31300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory