

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/127/25	Model No.: KMCRQ-10	Date: 08-09-2025
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 127/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 01261 To 1270	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01261 To 1270 and removed from the Lot/Batch							
1261	Pass	1262	Pass	1263	Pass	1264	Pass
1265	Pass	1266	Pass	1267	Pass	1268	Pass
1269	Pass	1270	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory