

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/128/25	Model No.: KMCRQ-10	Date: 11-09-2025
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 128/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 01271 To 1280	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01271 To 1280 and removed from the Lot/Batch							
1271	Pass	1272	Pass	1273	Pass	1274	Pass
1275	Pass	1276	Pass	1277	Pass	1278	Pass
1279	Pass	1280	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory