

# HYDRO PRESSURE TEST

|                                   |                                                                           |                  |
|-----------------------------------|---------------------------------------------------------------------------|------------------|
| TC No.: HPT/MOD10/A50/RQ/039/25   | Model No.: KMPRQ-10-50%                                                   | Date: 15-09-2025 |
| Type and Capacity of Extinguisher | : KMPRQ-10-50%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 10 Kg. |                  |
| Batch Number                      | : KMPRQ50%10 039/25                                                       |                  |
| Batch Quantity                    | : 20.00 Nos.                                                              |                  |
| Serial Numbers                    | : 00761 To 780                                                            |                  |
| Month of Manufacturing            | : Sep/25                                                                  |                  |

| Sr. Nos.                                                            | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|---------------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 00761 To 780 and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 761                                                                 | Pass   | 762      | Pass   | 763      | Pass   | 764      | Pass   |
| 765                                                                 | Pass   | 766      | Pass   | 767      | Pass   | 768      | Pass   |
| 769                                                                 | Pass   | 770      | Pass   | 771      | Pass   | 772      | Pass   |
| 773                                                                 | Pass   | 774      | Pass   | 775      | Pass   | 776      | Pass   |
| 777                                                                 | Pass   | 778      | Pass   | 779      | Pass   | 780      | Pass   |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



**Authorized Signatory**