

HYDRO PRESSURE TEST

TC No.: HPT/A2/A90/RQ/065/25	Model No.: KFARQ-2-90%	Date: 06-07-2025
Type and Capacity of Extinguisher	: KFARQ-2-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg.	
Batch Number	: KFARQ90%2 065/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 06401 To 6500 And 6405A	
Month of Manufacturing	: Jul/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 6405A and removed from the Lot/Batch							
6401	Pass	6402	Pass	6403	Pass	6404	Pass
6405	Pass	6406	Pass	6407	Pass	6408	Pass
6409	Pass	6410	Pass	6411	Pass	6412	Pass
6413	Pass	6414	Pass	6415	Pass	6416	Pass
6417	Pass	6418	Pass	6419	Pass	6420	Pass
6421	Pass	6422	Pass	6423	Pass	6424	Pass
6425	Pass	6426	Pass	6427	Pass	6428	Pass
6429	Pass	6430	Pass	6431	Pass	6432	Pass
6433	Pass	6434	Pass	6435	Pass	6436	Pass
6437	Pass	6438	Pass	6439	Pass	6440	Pass
6441	Pass	6442	Pass	6443	Pass	6444	Pass
6445	Pass	6446	Pass	6447	Pass	6448	Pass
6449	Pass	6450	Pass	6451	Pass	6452	Pass
6453	Pass	6454	Pass	6455	Pass	6456	Pass
6457	Pass	6458	Pass	6459	Pass	6460	Pass
6461	Pass	6462	Pass	6463	Pass	6464	Pass
6465	Pass	6466	Pass	6467	Pass	6468	Pass
6469	Pass	6470	Pass	6471	Pass	6472	Pass
6473	Pass	6474	Pass	6475	Pass	6476	Pass
6477	Pass	6478	Pass	6479	Pass	6480	Pass
6481	Pass	6482	Pass	6483	Pass	6484	Pass
6485	Pass	6486	Pass	6487	Pass	6488	Pass
6489	Pass	6490	Pass	6491	Pass	6492	Pass
6493	Pass	6494	Pass	6495	Pass	6496	Pass
6497	Pass	6498	Pass	6499	Pass	6500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory