

HYDRO PRESSURE TEST

TC No.: HPT/A4/K/HQ/015/25

Model No.: KFKHQ-4

Date: 03-07-2025

Type and Capacity of Extinguisher : KFKHQ-4-Kanex F Class Kitchen Fire Extinguisher Cap. 4 Ltr.

Batch Number : KFKHQ4 015/25

Batch Quantity : 10.00 Nos.

Serial Numbers : 00141 To 150

Month of Manufacturing : Jul/25

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
----------	--------	----------	--------	----------	--------	----------	--------

Burst test conducted on 00141 To 150 and removed from the Lot/Batch

141	Pass	142	Pass	143	Pass	144	Pass
145	Pass	146	Pass	147	Pass	148	Pass
149	Pass	150	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.

**Authorized Signatory**