



Warranty Certificate

Date: 01-11-2025**Manufacturer:** Kanex Fire Solutions Limited.**Customer Name:** Berger Paints India Limited**Warranty Start Date:** 01-11-2025**Warranty End Date:** 31-10-2026.

This is to certify that the below extinguishers are warranted for a period of **1** year from the date of supply against any of Manufacturing/Quality defects.

NOTE – IF TAMPER SEAL IS NOT INTACT, THE WARRANTY SHALL BE CONSIDERED VOID.

Sr.No.	Type & Capacity of Extinguishers	Quantity	Sr. Nos.
1	KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	4	As Per Annexure – I
2	KFCRQ-4.5-Kanex CO2 High Pressure Fire Extinguisher Cap. 4.5 Kg.	4	As Per Annexure – I
3	KFMSRQ-9-Kanex M Foam SP Fire Extinguisher Cap. 9 Ltr.	3	As Per Annexure – I

Also certify that, all the Fire extinguishers supplied against Invoice No. **25-26/K/005008 Dated: 01-11-2025 P.O.No. FE/19/KANEX/31/10/2025** are hydraulically tested 100% at 35 bar except CO2 and randomly tested for performance test. All the extinguishers confirms to IS 15683:2018 (Portable) or IS 16018:2012 (Mobile) requirements.

Note : If applicable CO2 Cylinders are PESO approved & HPT tested at 225 bar by Cylinder Manufacturer.

**Authorized Signatory**