

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/312/25	Model No.: MARQ-6-50%	Date: 10-10-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 312/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 31101 To 31200 And 31105A	
Month of Manufacturing	: Oct/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 31105A and removed from the Lot/Batch							
31101	Pass	31102	Pass	31103	Pass	31104	Pass
31105	Pass	31106	Pass	31107	Pass	31108	Pass
31109	Pass	31110	Pass	31111	Pass	31112	Pass
31113	Pass	31114	Pass	31115	Pass	31116	Pass
31117	Pass	31118	Pass	31119	Pass	31120	Pass
31121	Pass	31122	Pass	31123	Pass	31124	Pass
31125	Pass	31126	Pass	31127	Pass	31128	Pass
31129	Pass	31130	Pass	31131	Pass	31132	Pass
31133	Pass	31134	Pass	31135	Pass	31136	Pass
31137	Pass	31138	Pass	31139	Pass	31140	Pass
31141	Pass	31142	Pass	31143	Pass	31144	Pass
31145	Pass	31146	Pass	31147	Pass	31148	Pass
31149	Pass	31150	Pass	31151	Pass	31152	Pass
31153	Pass	31154	Pass	31155	Pass	31156	Pass
31157	Pass	31158	Pass	31159	Pass	31160	Pass
31161	Pass	31162	Pass	31163	Pass	31164	Pass
31165	Pass	31166	Pass	31167	Pass	31168	Pass
31169	Pass	31170	Pass	31171	Pass	31172	Pass
31173	Pass	31174	Pass	31175	Pass	31176	Pass
31177	Pass	31178	Pass	31179	Pass	31180	Pass
31181	Pass	31182	Pass	31183	Pass	31184	Pass
31185	Pass	31186	Pass	31187	Pass	31188	Pass
31189	Pass	31190	Pass	31191	Pass	31192	Pass
31193	Pass	31194	Pass	31195	Pass	31196	Pass
31197	Pass	31198	Pass	31199	Pass	31200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory