

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/231/25	Model No.: KFARQ-6-90%	Date: 22-08-2025
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 231/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 23001 To 23100 And 23005A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 23005A and removed from the Lot/Batch							
23001	Pass	23002	Pass	23003	Pass	23004	Pass
23005	Pass	23006	Pass	23007	Pass	23008	Pass
23009	Pass	23010	Pass	23011	Pass	23012	Pass
23013	Pass	23014	Pass	23015	Pass	23016	Pass
23017	Pass	23018	Pass	23019	Pass	23020	Pass
23021	Pass	23022	Pass	23023	Pass	23024	Pass
23025	Pass	23026	Pass	23027	Pass	23028	Pass
23029	Pass	23030	Pass	23031	Pass	23032	Pass
23033	Pass	23034	Pass	23035	Pass	23036	Pass
23037	Pass	23038	Pass	23039	Pass	23040	Pass
23041	Pass	23042	Pass	23043	Pass	23044	Pass
23045	Pass	23046	Pass	23047	Pass	23048	Pass
23049	Pass	23050	Pass	23051	Pass	23052	Pass
23053	Pass	23054	Pass	23055	Pass	23056	Pass
23057	Pass	23058	Pass	23059	Pass	23060	Pass
23061	Pass	23062	Pass	23063	Pass	23064	Pass
23065	Pass	23066	Pass	23067	Pass	23068	Pass
23069	Pass	23070	Pass	23071	Pass	23072	Pass
23073	Pass	23074	Pass	23075	Pass	23076	Pass
23077	Pass	23078	Pass	23079	Pass	23080	Pass
23081	Pass	23082	Pass	23083	Pass	23084	Pass
23085	Pass	23086	Pass	23087	Pass	23088	Pass
23089	Pass	23090	Pass	23091	Pass	23092	Pass
23093	Pass	23094	Pass	23095	Pass	23096	Pass
23097	Pass	23098	Pass	23099	Pass	23100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory