

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/172/25	Model No.: KFARQ-4-90%	Date: 26-09-2025
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 172/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 17101 To 17200 And 17105A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 17105A and removed from the Lot/Batch							
17101	Pass	17102	Pass	17103	Pass	17104	Pass
17105	Pass	17106	Pass	17107	Pass	17108	Pass
17109	Pass	17110	Pass	17111	Pass	17112	Pass
17113	Pass	17114	Pass	17115	Pass	17116	Pass
17117	Pass	17118	Pass	17119	Pass	17120	Pass
17121	Pass	17122	Pass	17123	Pass	17124	Pass
17125	Pass	17126	Pass	17127	Pass	17128	Pass
17129	Pass	17130	Pass	17131	Pass	17132	Pass
17133	Pass	17134	Pass	17135	Pass	17136	Pass
17137	Pass	17138	Pass	17139	Pass	17140	Pass
17141	Pass	17142	Pass	17143	Pass	17144	Pass
17145	Pass	17146	Pass	17147	Pass	17148	Pass
17149	Pass	17150	Pass	17151	Pass	17152	Pass
17153	Pass	17154	Pass	17155	Pass	17156	Pass
17157	Pass	17158	Pass	17159	Pass	17160	Pass
17161	Pass	17162	Pass	17163	Pass	17164	Pass
17165	Pass	17166	Pass	17167	Pass	17168	Pass
17169	Pass	17170	Pass	17171	Pass	17172	Pass
17173	Pass	17174	Pass	17175	Pass	17176	Pass
17177	Pass	17178	Pass	17179	Pass	17180	Pass
17181	Pass	17182	Pass	17183	Pass	17184	Pass
17185	Pass	17186	Pass	17187	Pass	17188	Pass
17189	Pass	17190	Pass	17191	Pass	17192	Pass
17193	Pass	17194	Pass	17195	Pass	17196	Pass
17197	Pass	17198	Pass	17199	Pass	17200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory