

HELIUM LEAK DETECTION TEST

TC No.: HLD/A9/K/HQ/043/25

Model No.: KFKHQ-9

Date: 16-10-2025

Type and Capacity of Extinguisher : KFKHQ-9-Kanex F Class Kitchen Fire Extinguisher Cap. 9 Ltr.

Batch Number : KFKHQ9 043/25

Batch Quantity : 10 Nos.

Serial Numbers : 00421 To 430

Month of Manufacturing : Oct/25

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
421	Pass	422	Pass	423	Pass	424	Pass
425	Pass	426	Pass	427	Pass	428	Pass
429	Pass	430	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.

**Authorized Signatory**