

# HYDRO PRESSURE TEST

|                                   |                                                                |                  |
|-----------------------------------|----------------------------------------------------------------|------------------|
| TC No.: HPT/MA9/A40/RQ/004/25     | Model No.: MARQ-9-90%                                          | Date: 11-09-2025 |
| Type and Capacity of Extinguisher | : MARQ-9-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 9 Kg. |                  |
| Batch Number                      | : MARQ90%9 004/25                                              |                  |
| Batch Quantity                    | : 101.00 Nos.                                                  |                  |
| Serial Numbers                    | : 00301 To 400 And 305A                                        |                  |
| Month of Manufacturing            | : Sep/25                                                       |                  |

| Sr. Nos.                                                    | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|-------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 305A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 301                                                         | Pass   | 302      | Pass   | 303      | Pass   | 304      | Pass   |
| 305                                                         | Pass   | 306      | Pass   | 307      | Pass   | 308      | Pass   |
| 309                                                         | Pass   | 310      | Pass   | 311      | Pass   | 312      | Pass   |
| 313                                                         | Pass   | 314      | Pass   | 315      | Pass   | 316      | Pass   |
| 317                                                         | Pass   | 318      | Pass   | 319      | Pass   | 320      | Pass   |
| 321                                                         | Pass   | 322      | Pass   | 323      | Pass   | 324      | Pass   |
| 325                                                         | Pass   | 326      | Pass   | 327      | Pass   | 328      | Pass   |
| 329                                                         | Pass   | 330      | Pass   | 331      | Pass   | 332      | Pass   |
| 333                                                         | Pass   | 334      | Pass   | 335      | Pass   | 336      | Pass   |
| 337                                                         | Pass   | 338      | Pass   | 339      | Pass   | 340      | Pass   |
| 341                                                         | Pass   | 342      | Pass   | 343      | Pass   | 344      | Pass   |
| 345                                                         | Pass   | 346      | Pass   | 347      | Pass   | 348      | Pass   |
| 349                                                         | Pass   | 350      | Pass   | 351      | Pass   | 352      | Pass   |
| 353                                                         | Pass   | 354      | Pass   | 355      | Pass   | 356      | Pass   |
| 357                                                         | Pass   | 358      | Pass   | 359      | Pass   | 360      | Pass   |
| 361                                                         | Pass   | 362      | Pass   | 363      | Pass   | 364      | Pass   |
| 365                                                         | Pass   | 366      | Pass   | 367      | Pass   | 368      | Pass   |
| 369                                                         | Pass   | 370      | Pass   | 371      | Pass   | 372      | Pass   |
| 373                                                         | Pass   | 374      | Pass   | 375      | Pass   | 376      | Pass   |
| 377                                                         | Pass   | 378      | Pass   | 379      | Pass   | 380      | Pass   |
| 381                                                         | Pass   | 382      | Pass   | 383      | Pass   | 384      | Pass   |
| 385                                                         | Pass   | 386      | Pass   | 387      | Pass   | 388      | Pass   |
| 389                                                         | Pass   | 390      | Pass   | 391      | Pass   | 392      | Pass   |
| 393                                                         | Pass   | 394      | Pass   | 395      | Pass   | 396      | Pass   |
| 397                                                         | Pass   | 398      | Pass   | 399      | Pass   | 400      | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**