

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/261/25	Model No.: MARQ-6-50%	Date: 03-08-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 261/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 26001 To 26100 And 26005A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 26005A and removed from the Lot/Batch							
26001	Pass	26002	Pass	26003	Pass	26004	Pass
26005	Pass	26006	Pass	26007	Pass	26008	Pass
26009	Pass	26010	Pass	26011	Pass	26012	Pass
26013	Pass	26014	Pass	26015	Pass	26016	Pass
26017	Pass	26018	Pass	26019	Pass	26020	Pass
26021	Pass	26022	Pass	26023	Pass	26024	Pass
26025	Pass	26026	Pass	26027	Pass	26028	Pass
26029	Pass	26030	Pass	26031	Pass	26032	Pass
26033	Pass	26034	Pass	26035	Pass	26036	Pass
26037	Pass	26038	Pass	26039	Pass	26040	Pass
26041	Pass	26042	Pass	26043	Pass	26044	Pass
26045	Pass	26046	Pass	26047	Pass	26048	Pass
26049	Pass	26050	Pass	26051	Pass	26052	Pass
26053	Pass	26054	Pass	26055	Pass	26056	Pass
26057	Pass	26058	Pass	26059	Pass	26060	Pass
26061	Pass	26062	Pass	26063	Pass	26064	Pass
26065	Pass	26066	Pass	26067	Pass	26068	Pass
26069	Pass	26070	Pass	26071	Pass	26072	Pass
26073	Pass	26074	Pass	26075	Pass	26076	Pass
26077	Pass	26078	Pass	26079	Pass	26080	Pass
26081	Pass	26082	Pass	26083	Pass	26084	Pass
26085	Pass	26086	Pass	26087	Pass	26088	Pass
26089	Pass	26090	Pass	26091	Pass	26092	Pass
26093	Pass	26094	Pass	26095	Pass	26096	Pass
26097	Pass	26098	Pass	26099	Pass	26100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory