

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/314/25	Model No.: KFARQ-6-50%	Date: 03-10-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 314/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 31301 To 31400 And 31305A	
Month of Manufacturing	: Oct/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 31305A and removed from the Lot/Batch							
31301	Pass	31302	Pass	31303	Pass	31304	Pass
31305	Pass	31306	Pass	31307	Pass	31308	Pass
31309	Pass	31310	Pass	31311	Pass	31312	Pass
31313	Pass	31314	Pass	31315	Pass	31316	Pass
31317	Pass	31318	Pass	31319	Pass	31320	Pass
31321	Pass	31322	Pass	31323	Pass	31324	Pass
31325	Pass	31326	Pass	31327	Pass	31328	Pass
31329	Pass	31330	Pass	31331	Pass	31332	Pass
31333	Pass	31334	Pass	31335	Pass	31336	Pass
31337	Pass	31338	Pass	31339	Pass	31340	Pass
31341	Pass	31342	Pass	31343	Pass	31344	Pass
31345	Pass	31346	Pass	31347	Pass	31348	Pass
31349	Pass	31350	Pass	31351	Pass	31352	Pass
31353	Pass	31354	Pass	31355	Pass	31356	Pass
31357	Pass	31358	Pass	31359	Pass	31360	Pass
31361	Pass	31362	Pass	31363	Pass	31364	Pass
31365	Pass	31366	Pass	31367	Pass	31368	Pass
31369	Pass	31370	Pass	31371	Pass	31372	Pass
31373	Pass	31374	Pass	31375	Pass	31376	Pass
31377	Pass	31378	Pass	31379	Pass	31380	Pass
31381	Pass	31382	Pass	31383	Pass	31384	Pass
31385	Pass	31386	Pass	31387	Pass	31388	Pass
31389	Pass	31390	Pass	31391	Pass	31392	Pass
31393	Pass	31394	Pass	31395	Pass	31396	Pass
31397	Pass	31398	Pass	31399	Pass	31400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory