

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/283/25	Model No.: MARQ-6-50%	Date: 05-09-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 283/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 28201 To 28300 And 28205A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 28205A and removed from the Lot/Batch							
28201	Pass	28202	Pass	28203	Pass	28204	Pass
28205	Pass	28206	Pass	28207	Pass	28208	Pass
28209	Pass	28210	Pass	28211	Pass	28212	Pass
28213	Pass	28214	Pass	28215	Pass	28216	Pass
28217	Pass	28218	Pass	28219	Pass	28220	Pass
28221	Pass	28222	Pass	28223	Pass	28224	Pass
28225	Pass	28226	Pass	28227	Pass	28228	Pass
28229	Pass	28230	Pass	28231	Pass	28232	Pass
28233	Pass	28234	Pass	28235	Pass	28236	Pass
28237	Pass	28238	Pass	28239	Pass	28240	Pass
28241	Pass	28242	Pass	28243	Pass	28244	Pass
28245	Pass	28246	Pass	28247	Pass	28248	Pass
28249	Pass	28250	Pass	28251	Pass	28252	Pass
28253	Pass	28254	Pass	28255	Pass	28256	Pass
28257	Pass	28258	Pass	28259	Pass	28260	Pass
28261	Pass	28262	Pass	28263	Pass	28264	Pass
28265	Pass	28266	Pass	28267	Pass	28268	Pass
28269	Pass	28270	Pass	28271	Pass	28272	Pass
28273	Pass	28274	Pass	28275	Pass	28276	Pass
28277	Pass	28278	Pass	28279	Pass	28280	Pass
28281	Pass	28282	Pass	28283	Pass	28284	Pass
28285	Pass	28286	Pass	28287	Pass	28288	Pass
28289	Pass	28290	Pass	28291	Pass	28292	Pass
28293	Pass	28294	Pass	28295	Pass	28296	Pass
28297	Pass	28298	Pass	28299	Pass	28300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory