

HYDRO PRESSURE TEST

TC No.: HPT/F9/SP/RQ/068/25	Model No.: KFMSRQ-9	Date: 27-10-2025
Type and Capacity of Extinguisher	: KFMSRQ-9-Kanex M Foam SP Fire Extinguisher Cap. 9 Ltr.	
Batch Number	: KFMSRQ9 068/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 06701 To 6800 And 6705A	
Month of Manufacturing	: Oct/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 6705A and removed from the Lot/Batch							
6701	Pass	6702	Pass	6703	Pass	6704	Pass
6705	Pass	6706	Pass	6707	Pass	6708	Pass
6709	Pass	6710	Pass	6711	Pass	6712	Pass
6713	Pass	6714	Pass	6715	Pass	6716	Pass
6717	Pass	6718	Pass	6719	Pass	6720	Pass
6721	Pass	6722	Pass	6723	Pass	6724	Pass
6725	Pass	6726	Pass	6727	Pass	6728	Pass
6729	Pass	6730	Pass	6731	Pass	6732	Pass
6733	Pass	6734	Pass	6735	Pass	6736	Pass
6737	Pass	6738	Pass	6739	Pass	6740	Pass
6741	Pass	6742	Pass	6743	Pass	6744	Pass
6745	Pass	6746	Pass	6747	Pass	6748	Pass
6749	Pass	6750	Pass	6751	Pass	6752	Pass
6753	Pass	6754	Pass	6755	Pass	6756	Pass
6757	Pass	6758	Pass	6759	Pass	6760	Pass
6761	Pass	6762	Pass	6763	Pass	6764	Pass
6765	Pass	6766	Pass	6767	Pass	6768	Pass
6769	Pass	6770	Pass	6771	Pass	6772	Pass
6773	Pass	6774	Pass	6775	Pass	6776	Pass
6777	Pass	6778	Pass	6779	Pass	6780	Pass
6781	Pass	6782	Pass	6783	Pass	6784	Pass
6785	Pass	6786	Pass	6787	Pass	6788	Pass
6789	Pass	6790	Pass	6791	Pass	6792	Pass
6793	Pass	6794	Pass	6795	Pass	6796	Pass
6797	Pass	6798	Pass	6799	Pass	6800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory