

HYDRO PRESSURE TEST

TC No.: HPT/MA1/A50/RQ/012/25	Model No.: MARQ-1-50%	Date: 13-10-2025
Type and Capacity of Extinguisher	: MARQ-1-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 1 Kg.	
Batch Number	: MARQ50%1 012/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 01101 To 1200 And 1105A	
Month of Manufacturing	: Oct/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 1105A and removed from the Lot/Batch							
1101	Pass	1102	Pass	1103	Pass	1104	Pass
1105	Pass	1106	Pass	1107	Pass	1108	Pass
1109	Pass	1110	Pass	1111	Pass	1112	Pass
1113	Pass	1114	Pass	1115	Pass	1116	Pass
1117	Pass	1118	Pass	1119	Pass	1120	Pass
1121	Pass	1122	Pass	1123	Pass	1124	Pass
1125	Pass	1126	Pass	1127	Pass	1128	Pass
1129	Pass	1130	Pass	1131	Pass	1132	Pass
1133	Pass	1134	Pass	1135	Pass	1136	Pass
1137	Pass	1138	Pass	1139	Pass	1140	Pass
1141	Pass	1142	Pass	1143	Pass	1144	Pass
1145	Pass	1146	Pass	1147	Pass	1148	Pass
1149	Pass	1150	Pass	1151	Pass	1152	Pass
1153	Pass	1154	Pass	1155	Pass	1156	Pass
1157	Pass	1158	Pass	1159	Pass	1160	Pass
1161	Pass	1162	Pass	1163	Pass	1164	Pass
1165	Pass	1166	Pass	1167	Pass	1168	Pass
1169	Pass	1170	Pass	1171	Pass	1172	Pass
1173	Pass	1174	Pass	1175	Pass	1176	Pass
1177	Pass	1178	Pass	1179	Pass	1180	Pass
1181	Pass	1182	Pass	1183	Pass	1184	Pass
1185	Pass	1186	Pass	1187	Pass	1188	Pass
1189	Pass	1190	Pass	1191	Pass	1192	Pass
1193	Pass	1194	Pass	1195	Pass	1196	Pass
1197	Pass	1198	Pass	1199	Pass	1200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory