

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/233/25	Model No.: KFARQ-6-90%	Date: 22-08-2025
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 233/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 23201 To 23300 And 23205A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 23205A and removed from the Lot/Batch							
23201	Pass	23202	Pass	23203	Pass	23204	Pass
23205	Pass	23206	Pass	23207	Pass	23208	Pass
23209	Pass	23210	Pass	23211	Pass	23212	Pass
23213	Pass	23214	Pass	23215	Pass	23216	Pass
23217	Pass	23218	Pass	23219	Pass	23220	Pass
23221	Pass	23222	Pass	23223	Pass	23224	Pass
23225	Pass	23226	Pass	23227	Pass	23228	Pass
23229	Pass	23230	Pass	23231	Pass	23232	Pass
23233	Pass	23234	Pass	23235	Pass	23236	Pass
23237	Pass	23238	Pass	23239	Pass	23240	Pass
23241	Pass	23242	Pass	23243	Pass	23244	Pass
23245	Pass	23246	Pass	23247	Pass	23248	Pass
23249	Pass	23250	Pass	23251	Pass	23252	Pass
23253	Pass	23254	Pass	23255	Pass	23256	Pass
23257	Pass	23258	Pass	23259	Pass	23260	Pass
23261	Pass	23262	Pass	23263	Pass	23264	Pass
23265	Pass	23266	Pass	23267	Pass	23268	Pass
23269	Pass	23270	Pass	23271	Pass	23272	Pass
23273	Pass	23274	Pass	23275	Pass	23276	Pass
23277	Pass	23278	Pass	23279	Pass	23280	Pass
23281	Pass	23282	Pass	23283	Pass	23284	Pass
23285	Pass	23286	Pass	23287	Pass	23288	Pass
23289	Pass	23290	Pass	23291	Pass	23292	Pass
23293	Pass	23294	Pass	23295	Pass	23296	Pass
23297	Pass	23298	Pass	23299	Pass	23300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory