

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/173/25	Model No.: KFARQ-4-90%	Date: 26-09-2025
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 173/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 17201 To 17300 And 17205A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 17205A and removed from the Lot/Batch							
17201	Pass	17202	Pass	17203	Pass	17204	Pass
17205	Pass	17206	Pass	17207	Pass	17208	Pass
17209	Pass	17210	Pass	17211	Pass	17212	Pass
17213	Pass	17214	Pass	17215	Pass	17216	Pass
17217	Pass	17218	Pass	17219	Pass	17220	Pass
17221	Pass	17222	Pass	17223	Pass	17224	Pass
17225	Pass	17226	Pass	17227	Pass	17228	Pass
17229	Pass	17230	Pass	17231	Pass	17232	Pass
17233	Pass	17234	Pass	17235	Pass	17236	Pass
17237	Pass	17238	Pass	17239	Pass	17240	Pass
17241	Pass	17242	Pass	17243	Pass	17244	Pass
17245	Pass	17246	Pass	17247	Pass	17248	Pass
17249	Pass	17250	Pass	17251	Pass	17252	Pass
17253	Pass	17254	Pass	17255	Pass	17256	Pass
17257	Pass	17258	Pass	17259	Pass	17260	Pass
17261	Pass	17262	Pass	17263	Pass	17264	Pass
17265	Pass	17266	Pass	17267	Pass	17268	Pass
17269	Pass	17270	Pass	17271	Pass	17272	Pass
17273	Pass	17274	Pass	17275	Pass	17276	Pass
17277	Pass	17278	Pass	17279	Pass	17280	Pass
17281	Pass	17282	Pass	17283	Pass	17284	Pass
17285	Pass	17286	Pass	17287	Pass	17288	Pass
17289	Pass	17290	Pass	17291	Pass	17292	Pass
17293	Pass	17294	Pass	17295	Pass	17296	Pass
17297	Pass	17298	Pass	17299	Pass	17300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory