

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/165/25	Model No.: MARQ-6-50%	Date: 27-05-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 165/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 16401 To 16500 And 16405A	
Month of Manufacturing	: May/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 16405A and removed from the Lot/Batch							
16401	Pass	16402	Pass	16403	Pass	16404	Pass
16405	Pass	16406	Pass	16407	Pass	16408	Pass
16409	Pass	16410	Pass	16411	Pass	16412	Pass
16413	Pass	16414	Pass	16415	Pass	16416	Pass
16417	Pass	16418	Pass	16419	Pass	16420	Pass
16421	Pass	16422	Pass	16423	Pass	16424	Pass
16425	Pass	16426	Pass	16427	Pass	16428	Pass
16429	Pass	16430	Pass	16431	Pass	16432	Pass
16433	Pass	16434	Pass	16435	Pass	16436	Pass
16437	Pass	16438	Pass	16439	Pass	16440	Pass
16441	Pass	16442	Pass	16443	Pass	16444	Pass
16445	Pass	16446	Pass	16447	Pass	16448	Pass
16449	Pass	16450	Pass	16451	Pass	16452	Pass
16453	Pass	16454	Pass	16455	Pass	16456	Pass
16457	Pass	16458	Pass	16459	Pass	16460	Pass
16461	Pass	16462	Pass	16463	Pass	16464	Pass
16465	Pass	16466	Pass	16467	Pass	16468	Pass
16469	Pass	16470	Pass	16471	Pass	16472	Pass
16473	Pass	16474	Pass	16475	Pass	16476	Pass
16477	Pass	16478	Pass	16479	Pass	16480	Pass
16481	Pass	16482	Pass	16483	Pass	16484	Pass
16485	Pass	16486	Pass	16487	Pass	16488	Pass
16489	Pass	16490	Pass	16491	Pass	16492	Pass
16493	Pass	16494	Pass	16495	Pass	16496	Pass
16497	Pass	16498	Pass	16499	Pass	16500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory