

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/209/25	Model No.: MARQ-6-50%	Date: 26-06-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 209/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 20801 To 20900 And 20805A	
Month of Manufacturing	: Jun/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 20805A and removed from the Lot/Batch							
20801	Pass	20802	Pass	20803	Pass	20804	Pass
20805	Pass	20806	Pass	20807	Pass	20808	Pass
20809	Pass	20810	Pass	20811	Pass	20812	Pass
20813	Pass	20814	Pass	20815	Pass	20816	Pass
20817	Pass	20818	Pass	20819	Pass	20820	Pass
20821	Pass	20822	Pass	20823	Pass	20824	Pass
20825	Pass	20826	Pass	20827	Pass	20828	Pass
20829	Pass	20830	Pass	20831	Pass	20832	Pass
20833	Pass	20834	Pass	20835	Pass	20836	Pass
20837	Pass	20838	Pass	20839	Pass	20840	Pass
20841	Pass	20842	Pass	20843	Pass	20844	Pass
20845	Pass	20846	Pass	20847	Pass	20848	Pass
20849	Pass	20850	Pass	20851	Pass	20852	Pass
20853	Pass	20854	Pass	20855	Pass	20856	Pass
20857	Pass	20858	Pass	20859	Pass	20860	Pass
20861	Pass	20862	Pass	20863	Pass	20864	Pass
20865	Pass	20866	Pass	20867	Pass	20868	Pass
20869	Pass	20870	Pass	20871	Pass	20872	Pass
20873	Pass	20874	Pass	20875	Pass	20876	Pass
20877	Pass	20878	Pass	20879	Pass	20880	Pass
20881	Pass	20882	Pass	20883	Pass	20884	Pass
20885	Pass	20886	Pass	20887	Pass	20888	Pass
20889	Pass	20890	Pass	20891	Pass	20892	Pass
20893	Pass	20894	Pass	20895	Pass	20896	Pass
20897	Pass	20898	Pass	20899	Pass	20900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory