

HYDRO PRESSURE TEST

TC No.: HPT/F45/RQ/040/25	Model No.: KFMRQ-45	Date: 08-09-2025
Type and Capacity of Extinguisher	: KFMRQ-45-Kanex M Foam Trolley Mounted Fire Extinguisher Cap. 45 Ltr.	
Batch Number	: KFMRQ45 040/25	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 01951 To 2000	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on Cylinder Sr.No.1505A and which is removed from the batch (31st batch)							
1951	Pass	1952	Pass	1953	Pass	1954	Pass
1955	Pass	1956	Pass	1957	Pass	1958	Pass
1959	Pass	1960	Pass	1961	Pass	1962	Pass
1963	Pass	1964	Pass	1965	Pass	1966	Pass
1967	Pass	1968	Pass	1969	Pass	1970	Pass
1971	Pass	1972	Pass	1973	Pass	1974	Pass
1975	Pass	1976	Pass	1977	Pass	1978	Pass
1979	Pass	1980	Pass	1981	Pass	1982	Pass
1983	Pass	1984	Pass	1985	Pass	1986	Pass
1987	Pass	1988	Pass	1989	Pass	1990	Pass
1991	Pass	1992	Pass	1993	Pass	1994	Pass
1995	Pass	1996	Pass	1997	Pass	1998	Pass
1999	Pass	2000	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



Authorized Signatory