

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/186/25	Model No.: MARQ-6-40%	Date: 26-09-2025
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 186/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 18501 To 18600 And 18505A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 18505A and removed from the Lot/Batch							
18501	Pass	18502	Pass	18503	Pass	18504	Pass
18505	Pass	18506	Pass	18507	Pass	18508	Pass
18509	Pass	18510	Pass	18511	Pass	18512	Pass
18513	Pass	18514	Pass	18515	Pass	18516	Pass
18517	Pass	18518	Pass	18519	Pass	18520	Pass
18521	Pass	18522	Pass	18523	Pass	18524	Pass
18525	Pass	18526	Pass	18527	Pass	18528	Pass
18529	Pass	18530	Pass	18531	Pass	18532	Pass
18533	Pass	18534	Pass	18535	Pass	18536	Pass
18537	Pass	18538	Pass	18539	Pass	18540	Pass
18541	Pass	18542	Pass	18543	Pass	18544	Pass
18545	Pass	18546	Pass	18547	Pass	18548	Pass
18549	Pass	18550	Pass	18551	Pass	18552	Pass
18553	Pass	18554	Pass	18555	Pass	18556	Pass
18557	Pass	18558	Pass	18559	Pass	18560	Pass
18561	Pass	18562	Pass	18563	Pass	18564	Pass
18565	Pass	18566	Pass	18567	Pass	18568	Pass
18569	Pass	18570	Pass	18571	Pass	18572	Pass
18573	Pass	18574	Pass	18575	Pass	18576	Pass
18577	Pass	18578	Pass	18579	Pass	18580	Pass
18581	Pass	18582	Pass	18583	Pass	18584	Pass
18585	Pass	18586	Pass	18587	Pass	18588	Pass
18589	Pass	18590	Pass	18591	Pass	18592	Pass
18593	Pass	18594	Pass	18595	Pass	18596	Pass
18597	Pass	18598	Pass	18599	Pass	18600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory