

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/265/25	Model No.: KFARQ-6-90%	Date: 04-10-2025
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 265/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 26401 To 26500 And 26405A	
Month of Manufacturing	: Oct/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 26405A and removed from the Lot/Batch							
26401	Pass	26402	Pass	26403	Pass	26404	Pass
26405	Pass	26406	Pass	26407	Pass	26408	Pass
26409	Pass	26410	Pass	26411	Pass	26412	Pass
26413	Pass	26414	Pass	26415	Pass	26416	Pass
26417	Pass	26418	Pass	26419	Pass	26420	Pass
26421	Pass	26422	Pass	26423	Pass	26424	Pass
26425	Pass	26426	Pass	26427	Pass	26428	Pass
26429	Pass	26430	Pass	26431	Pass	26432	Pass
26433	Pass	26434	Pass	26435	Pass	26436	Pass
26437	Pass	26438	Pass	26439	Pass	26440	Pass
26441	Pass	26442	Pass	26443	Pass	26444	Pass
26445	Pass	26446	Pass	26447	Pass	26448	Pass
26449	Pass	26450	Pass	26451	Pass	26452	Pass
26453	Pass	26454	Pass	26455	Pass	26456	Pass
26457	Pass	26458	Pass	26459	Pass	26460	Pass
26461	Pass	26462	Pass	26463	Pass	26464	Pass
26465	Pass	26466	Pass	26467	Pass	26468	Pass
26469	Pass	26470	Pass	26471	Pass	26472	Pass
26473	Pass	26474	Pass	26475	Pass	26476	Pass
26477	Pass	26478	Pass	26479	Pass	26480	Pass
26481	Pass	26482	Pass	26483	Pass	26484	Pass
26485	Pass	26486	Pass	26487	Pass	26488	Pass
26489	Pass	26490	Pass	26491	Pass	26492	Pass
26493	Pass	26494	Pass	26495	Pass	26496	Pass
26497	Pass	26498	Pass	26499	Pass	26500	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory