

# HYDRO PRESSURE TEST

|                                   |                                                               |                  |
|-----------------------------------|---------------------------------------------------------------|------------------|
| TC No.: HPT/CA4/HQ/014/25         | Model No.: KCAHQ-4-FE36                                       | Date: 15-09-2025 |
| Type and Capacity of Extinguisher | : KCAHQ-4-FE36-Kanex Clean Agent Fire Extinguisher Cap. 4 Kg. |                  |
| Batch Number                      | : KCAHQ4 014/25                                               |                  |
| Batch Quantity                    | : 101.00 Nos.                                                 |                  |
| Serial Numbers                    | : 01301 To 1400 And 1305A                                     |                  |
| Month of Manufacturing            | : Sep/25                                                      |                  |

| Sr. Nos.                                                     | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|--------------------------------------------------------------|--------|----------|--------|----------|--------|----------|--------|
| Burst test conducted on 1305A and removed from the Lot/Batch |        |          |        |          |        |          |        |
| 1301                                                         | Pass   | 1302     | Pass   | 1303     | Pass   | 1304     | Pass   |
| 1305                                                         | Pass   | 1306     | Pass   | 1307     | Pass   | 1308     | Pass   |
| 1309                                                         | Pass   | 1310     | Pass   | 1311     | Pass   | 1312     | Pass   |
| 1313                                                         | Pass   | 1314     | Pass   | 1315     | Pass   | 1316     | Pass   |
| 1317                                                         | Pass   | 1318     | Pass   | 1319     | Pass   | 1320     | Pass   |
| 1321                                                         | Pass   | 1322     | Pass   | 1323     | Pass   | 1324     | Pass   |
| 1325                                                         | Pass   | 1326     | Pass   | 1327     | Pass   | 1328     | Pass   |
| 1329                                                         | Pass   | 1330     | Pass   | 1331     | Pass   | 1332     | Pass   |
| 1333                                                         | Pass   | 1334     | Pass   | 1335     | Pass   | 1336     | Pass   |
| 1337                                                         | Pass   | 1338     | Pass   | 1339     | Pass   | 1340     | Pass   |
| 1341                                                         | Pass   | 1342     | Pass   | 1343     | Pass   | 1344     | Pass   |
| 1345                                                         | Pass   | 1346     | Pass   | 1347     | Pass   | 1348     | Pass   |
| 1349                                                         | Pass   | 1350     | Pass   | 1351     | Pass   | 1352     | Pass   |
| 1353                                                         | Pass   | 1354     | Pass   | 1355     | Pass   | 1356     | Pass   |
| 1357                                                         | Pass   | 1358     | Pass   | 1359     | Pass   | 1360     | Pass   |
| 1361                                                         | Pass   | 1362     | Pass   | 1363     | Pass   | 1364     | Pass   |
| 1365                                                         | Pass   | 1366     | Pass   | 1367     | Pass   | 1368     | Pass   |
| 1369                                                         | Pass   | 1370     | Pass   | 1371     | Pass   | 1372     | Pass   |
| 1373                                                         | Pass   | 1374     | Pass   | 1375     | Pass   | 1376     | Pass   |
| 1377                                                         | Pass   | 1378     | Pass   | 1379     | Pass   | 1380     | Pass   |
| 1381                                                         | Pass   | 1382     | Pass   | 1383     | Pass   | 1384     | Pass   |
| 1385                                                         | Pass   | 1386     | Pass   | 1387     | Pass   | 1388     | Pass   |
| 1389                                                         | Pass   | 1390     | Pass   | 1391     | Pass   | 1392     | Pass   |
| 1393                                                         | Pass   | 1394     | Pass   | 1395     | Pass   | 1396     | Pass   |
| 1397                                                         | Pass   | 1398     | Pass   | 1399     | Pass   | 1400     | Pass   |

**Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.**



**Authorized Signatory**