

HYDRO PRESSURE TEST

TC No.: HPT/KF/LI/HQ4/012/25

Model No.: KFLIHQ-4

Date: 12-07-2025

Type and Capacity of Extinguisher : KFLIHQ-4-Lithium-Ion (AVD) Stored Pressure Fire Extinguisher 4 Ltr.

Batch Number : KFLIHQ4 012/25

Batch Quantity : 11.00 Nos.

Serial Numbers : 00111 To 120 And 115A

Month of Manufacturing : Jul/25

Sr. Nos.

Result

Sr. Nos.

Result

Sr. Nos.

Result

Sr. Nos.

Result

Burst test conducted on 115A and removed from the Lot/Batch

111	Pass	112	Pass	113	Pass	114	Pass
115	Pass	116	Pass	117	Pass	118	Pass
119	Pass	120	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.

**Authorized Signatory**