

HYDRO PRESSURE TEST

TC No.: HPT/MOD2/A50/RQ/018/25	Model No.: KMPRQ-2-50%	Date: 26-09-2025
Type and Capacity of Extinguisher	: KMPRQ-2-50%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 2 Kg.	
Batch Number	: KMPRQ50%2 018/25	
Batch Quantity	: 20.00 Nos.	
Serial Numbers	: 00341 To 360	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 00341 To 360 and removed from the Lot/Batch							
341	Pass	342	Pass	343	Pass	344	Pass
345	Pass	346	Pass	347	Pass	348	Pass
349	Pass	350	Pass	351	Pass	352	Pass
353	Pass	354	Pass	355	Pass	356	Pass
357	Pass	358	Pass	359	Pass	360	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory