

HYDRO PRESSURE TEST

TC No.: HPT/A6/A90/RQ/266/25	Model No.: KFARQ-6-90%	Date: 04-10-2025
Type and Capacity of Extinguisher	: KFARQ-6-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ90%6 266/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 26501 To 26600 And 26505A	
Month of Manufacturing	: Oct/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 26505A and removed from the Lot/Batch							
26501	Pass	26502	Pass	26503	Pass	26504	Pass
26505	Pass	26506	Pass	26507	Pass	26508	Pass
26509	Pass	26510	Pass	26511	Pass	26512	Pass
26513	Pass	26514	Pass	26515	Pass	26516	Pass
26517	Pass	26518	Pass	26519	Pass	26520	Pass
26521	Pass	26522	Pass	26523	Pass	26524	Pass
26525	Pass	26526	Pass	26527	Pass	26528	Pass
26529	Pass	26530	Pass	26531	Pass	26532	Pass
26533	Pass	26534	Pass	26535	Pass	26536	Pass
26537	Pass	26538	Pass	26539	Pass	26540	Pass
26541	Pass	26542	Pass	26543	Pass	26544	Pass
26545	Pass	26546	Pass	26547	Pass	26548	Pass
26549	Pass	26550	Pass	26551	Pass	26552	Pass
26553	Pass	26554	Pass	26555	Pass	26556	Pass
26557	Pass	26558	Pass	26559	Pass	26560	Pass
26561	Pass	26562	Pass	26563	Pass	26564	Pass
26565	Pass	26566	Pass	26567	Pass	26568	Pass
26569	Pass	26570	Pass	26571	Pass	26572	Pass
26573	Pass	26574	Pass	26575	Pass	26576	Pass
26577	Pass	26578	Pass	26579	Pass	26580	Pass
26581	Pass	26582	Pass	26583	Pass	26584	Pass
26585	Pass	26586	Pass	26587	Pass	26588	Pass
26589	Pass	26590	Pass	26591	Pass	26592	Pass
26593	Pass	26594	Pass	26595	Pass	26596	Pass
26597	Pass	26598	Pass	26599	Pass	26600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory