

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/216/25	Model No.: MARQ-6-50%	Date: 26-06-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 216/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 21501 To 21600 And 21505A	
Month of Manufacturing	: Jun/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 21505A and removed from the Lot/Batch							
21501	Pass	21502	Pass	21503	Pass	21504	Pass
21505	Pass	21506	Pass	21507	Pass	21508	Pass
21509	Pass	21510	Pass	21511	Pass	21512	Pass
21513	Pass	21514	Pass	21515	Pass	21516	Pass
21517	Pass	21518	Pass	21519	Pass	21520	Pass
21521	Pass	21522	Pass	21523	Pass	21524	Pass
21525	Pass	21526	Pass	21527	Pass	21528	Pass
21529	Pass	21530	Pass	21531	Pass	21532	Pass
21533	Pass	21534	Pass	21535	Pass	21536	Pass
21537	Pass	21538	Pass	21539	Pass	21540	Pass
21541	Pass	21542	Pass	21543	Pass	21544	Pass
21545	Pass	21546	Pass	21547	Pass	21548	Pass
21549	Pass	21550	Pass	21551	Pass	21552	Pass
21553	Pass	21554	Pass	21555	Pass	21556	Pass
21557	Pass	21558	Pass	21559	Pass	21560	Pass
21561	Pass	21562	Pass	21563	Pass	21564	Pass
21565	Pass	21566	Pass	21567	Pass	21568	Pass
21569	Pass	21570	Pass	21571	Pass	21572	Pass
21573	Pass	21574	Pass	21575	Pass	21576	Pass
21577	Pass	21578	Pass	21579	Pass	21580	Pass
21581	Pass	21582	Pass	21583	Pass	21584	Pass
21585	Pass	21586	Pass	21587	Pass	21588	Pass
21589	Pass	21590	Pass	21591	Pass	21592	Pass
21593	Pass	21594	Pass	21595	Pass	21596	Pass
21597	Pass	21598	Pass	21599	Pass	21600	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory