

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/142/25	Model No.: MARQ-6-50%	Date: 26-04-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 142/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 14101 To 14200 And 14105A	
Month of Manufacturing	: Apr/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 14105A and removed from the Lot/Batch							
14101	Pass	14102	Pass	14103	Pass	14104	Pass
14105	Pass	14106	Pass	14107	Pass	14108	Pass
14109	Pass	14110	Pass	14111	Pass	14112	Pass
14113	Pass	14114	Pass	14115	Pass	14116	Pass
14117	Pass	14118	Pass	14119	Pass	14120	Pass
14121	Pass	14122	Pass	14123	Pass	14124	Pass
14125	Pass	14126	Pass	14127	Pass	14128	Pass
14129	Pass	14130	Pass	14131	Pass	14132	Pass
14133	Pass	14134	Pass	14135	Pass	14136	Pass
14137	Pass	14138	Pass	14139	Pass	14140	Pass
14141	Pass	14142	Pass	14143	Pass	14144	Pass
14145	Pass	14146	Pass	14147	Pass	14148	Pass
14149	Pass	14150	Pass	14151	Pass	14152	Pass
14153	Pass	14154	Pass	14155	Pass	14156	Pass
14157	Pass	14158	Pass	14159	Pass	14160	Pass
14161	Pass	14162	Pass	14163	Pass	14164	Pass
14165	Pass	14166	Pass	14167	Pass	14168	Pass
14169	Pass	14170	Pass	14171	Pass	14172	Pass
14173	Pass	14174	Pass	14175	Pass	14176	Pass
14177	Pass	14178	Pass	14179	Pass	14180	Pass
14181	Pass	14182	Pass	14183	Pass	14184	Pass
14185	Pass	14186	Pass	14187	Pass	14188	Pass
14189	Pass	14190	Pass	14191	Pass	14192	Pass
14193	Pass	14194	Pass	14195	Pass	14196	Pass
14197	Pass	14198	Pass	14199	Pass	14200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory