

HELIUM LEAK DETECTION TEST

TC No.: HLD/A6/K/HQ/106/25	Model No.: KFKHQ-6	Date: 28-09-2025
Type and Capacity of Extinguisher	: KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: KFKHQ6 106/25	
Batch Quantity	: 10 Nos.	
Serial Numbers	: 01051 To 1060	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
1051	Pass	1052	Pass	1053	Pass	1054	Pass
1055	Pass	1056	Pass	1057	Pass	1058	Pass
1059	Pass	1060	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of 1×10^{-6} mbar.l/sec and no any cylinders shows leakage beyond this limit.



Authorized Signatory