

HYDRO PRESSURE TEST

TC No.: HPT/A4/A90/RQ/171/25	Model No.: KFARQ-4-90%	Date: 26-09-2025
Type and Capacity of Extinguisher	: KFARQ-4-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFARQ90%4 171/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 17001 To 17100 And 17005A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 17005A and removed from the Lot/Batch							
17001	Pass	17002	Pass	17003	Pass	17004	Pass
17005	Pass	17006	Pass	17007	Pass	17008	Pass
17009	Pass	17010	Pass	17011	Pass	17012	Pass
17013	Pass	17014	Pass	17015	Pass	17016	Pass
17017	Pass	17018	Pass	17019	Pass	17020	Pass
17021	Pass	17022	Pass	17023	Pass	17024	Pass
17025	Pass	17026	Pass	17027	Pass	17028	Pass
17029	Pass	17030	Pass	17031	Pass	17032	Pass
17033	Pass	17034	Pass	17035	Pass	17036	Pass
17037	Pass	17038	Pass	17039	Pass	17040	Pass
17041	Pass	17042	Pass	17043	Pass	17044	Pass
17045	Pass	17046	Pass	17047	Pass	17048	Pass
17049	Pass	17050	Pass	17051	Pass	17052	Pass
17053	Pass	17054	Pass	17055	Pass	17056	Pass
17057	Pass	17058	Pass	17059	Pass	17060	Pass
17061	Pass	17062	Pass	17063	Pass	17064	Pass
17065	Pass	17066	Pass	17067	Pass	17068	Pass
17069	Pass	17070	Pass	17071	Pass	17072	Pass
17073	Pass	17074	Pass	17075	Pass	17076	Pass
17077	Pass	17078	Pass	17079	Pass	17080	Pass
17081	Pass	17082	Pass	17083	Pass	17084	Pass
17085	Pass	17086	Pass	17087	Pass	17088	Pass
17089	Pass	17090	Pass	17091	Pass	17092	Pass
17093	Pass	17094	Pass	17095	Pass	17096	Pass
17097	Pass	17098	Pass	17099	Pass	17100	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory