



Warranty Certificate

Date: 17-11-2025**Manufacturer:** Kanex Fire Solutions Limited.**Customer Name:** Bharti Airtel Limited**Warranty Start Date:** 17-11-2025**Warranty End Date:** 16-11-2026.

This is to certify that the below extinguishers are warranted for a period of **1** year from the date of supply against any of Manufacturing/Quality defects.

NOTE – IF TAMPER SEAL IS NOT INTACT, THE WARRANTY SHALL BE CONSIDERED VOID.

Sr.No.	Type & Capacity of Extinguishers	Quantity	Sr. Nos.
1	KCARQ-4-Kanex Clean Agent HFC Based Fire Extinguisher Cap. 4 Kg.	1	As Per Annexure – I
2	KFCRQ-4.5-Kanex CO2 High Pressure Fire Extinguisher Cap. 4.5 Kg.	2	As Per Annexure – I
3	MARQ-2-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 2 Kg.	7	As Per Annexure – I
4	MARQ-4-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 4 Kg.	2	As Per Annexure – I
5	MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	1	As Per Annexure – I

Also certify that, all the Fire extinguishers supplied against Invoice No. **25-26/K/005431 Dated: 17-11-2025 P.O.No. BAL-MO-HP-HP/PUR/10008833 PO** are hydraulically tested 100% at 35 bar except CO2 and randomly tested for performance test. All the extinguishers confirms to IS 15683:2018 (Portable) or IS 16018:2012 (Mobile) requirements.

Note : If applicable CO2 Cylinders are PESO approved & HPT tested at 225 bar by Cylinder Manufacturer.

**Authorized Signatory**