

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/219/25	Model No.: MARQ-6-50%	Date: 26-06-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 219/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 21801 To 21900 And 21805A	
Month of Manufacturing	: Jun/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 21805A and removed from the Lot/Batch							
21801	Pass	21802	Pass	21803	Pass	21804	Pass
21805	Pass	21806	Pass	21807	Pass	21808	Pass
21809	Pass	21810	Pass	21811	Pass	21812	Pass
21813	Pass	21814	Pass	21815	Pass	21816	Pass
21817	Pass	21818	Pass	21819	Pass	21820	Pass
21821	Pass	21822	Pass	21823	Pass	21824	Pass
21825	Pass	21826	Pass	21827	Pass	21828	Pass
21829	Pass	21830	Pass	21831	Pass	21832	Pass
21833	Pass	21834	Pass	21835	Pass	21836	Pass
21837	Pass	21838	Pass	21839	Pass	21840	Pass
21841	Pass	21842	Pass	21843	Pass	21844	Pass
21845	Pass	21846	Pass	21847	Pass	21848	Pass
21849	Pass	21850	Pass	21851	Pass	21852	Pass
21853	Pass	21854	Pass	21855	Pass	21856	Pass
21857	Pass	21858	Pass	21859	Pass	21860	Pass
21861	Pass	21862	Pass	21863	Pass	21864	Pass
21865	Pass	21866	Pass	21867	Pass	21868	Pass
21869	Pass	21870	Pass	21871	Pass	21872	Pass
21873	Pass	21874	Pass	21875	Pass	21876	Pass
21877	Pass	21878	Pass	21879	Pass	21880	Pass
21881	Pass	21882	Pass	21883	Pass	21884	Pass
21885	Pass	21886	Pass	21887	Pass	21888	Pass
21889	Pass	21890	Pass	21891	Pass	21892	Pass
21893	Pass	21894	Pass	21895	Pass	21896	Pass
21897	Pass	21898	Pass	21899	Pass	21900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory