

HYDRO PRESSURE TEST

TC No.: HPT/A6/K/HQ/087/25	Model No.: KFKHQ-6	Date: 21-09-2025
Type and Capacity of Extinguisher	: KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: KFKHQ6 087/25	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00861 To 870 And 865A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 865A and removed from the Lot/Batch							
861	Pass	862	Pass	863	Pass	864	Pass
865	Pass	866	Pass	867	Pass	868	Pass
869	Pass	870	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory