



Warranty Certificate

Date: 18-11-2025**Manufacturer:** Kanex Fire Solutions Limited.**Customer Name:** Aadeshwar Enterprise - A'bad**Warranty Start Date:** 18-11-2025**Warranty End Date:** 17-11-2026.

This is to certify that the below extinguishers are warranted for a period of **1** year from the date of supply against any of Manufacturing/Quality defects.

NOTE – IF TAMPER SEAL IS NOT INTACT, THE WARRANTY SHALL BE CONSIDERED VOID.

Sr.No.	Type & Capacity of Extinguishers	Quantity	Sr. Nos.
1	KFARQ-1-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 1 Kg.	10	As Per Annexure – I
2	KFCRQ-4.5-Kanex CO2 High Pressure Fire Extinguisher Cap. 4.5 Kg.	50	As Per Annexure – I
3	KFCRQ-6.5-Kanex CO2 High Pressure Fire Extinguisher Cap. 6.5 Kg.	11	As Per Annexure – I
4	KFDMSRQ-4-Kanex D Type Metal SP Fire Extinguisher Cap. 4 Kg.	2	As Per Annexure – I
5	KMPRQ-5-50%-Kanex Modular ABC Dry Powder Fire Extinguisher Cap. 5 Kg.	5	As Per Annexure – I
6	MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	20	As Per Annexure – I
7	MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	50	As Per Annexure – I
8	MARQ-9-90%-Kanex ABC Dry Powder Fire Extinguisher Cap. 9 Kg.	6	As Per Annexure – I

Also certify that, all the Fire extinguishers supplied against Invoice No. **25-26/K/005452 Dated: 18-11-2025 P.O.No. MAIL 17-11-2025** are hydraulically tested 100% at 35 bar except CO2 and randomly tested for performance test. All the extinguishers confirms to IS 15683:2018 (Portable) or IS 16018:2012 (Mobile) requirements.

Note : If applicable CO2 Cylinders are PESO approved & HPT tested at 225 bar by Cylinder Manufacturer.

**Authorized Signatory**