

HYDRO PRESSURE TEST

TC No.: HPT/A4/M/RQ/010/25	Model No.: KFDMSRQ-4	Date: 03-08-2025
Type and Capacity of Extinguisher	: KFDMSRQ-4-Kanex D Type Metal SP Fire Extinguisher Cap. 4 Kg.	
Batch Number	: KFDMSRQ4 010/25	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 00091 To 100 And 95A	
Month of Manufacturing	: Aug/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 95A and removed from the Lot/Batch							
91	Pass	92	Pass	93	Pass	94	Pass
95	Pass	96	Pass	97	Pass	98	Pass
99	Pass	100	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory