

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/274/25	Model No.: MARQ-6-50%	Date: 05-09-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 274/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 27301 To 27400 And 27305A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 27305A and removed from the Lot/Batch							
27301	Pass	27302	Pass	27303	Pass	27304	Pass
27305	Pass	27306	Pass	27307	Pass	27308	Pass
27309	Pass	27310	Pass	27311	Pass	27312	Pass
27313	Pass	27314	Pass	27315	Pass	27316	Pass
27317	Pass	27318	Pass	27319	Pass	27320	Pass
27321	Pass	27322	Pass	27323	Pass	27324	Pass
27325	Pass	27326	Pass	27327	Pass	27328	Pass
27329	Pass	27330	Pass	27331	Pass	27332	Pass
27333	Pass	27334	Pass	27335	Pass	27336	Pass
27337	Pass	27338	Pass	27339	Pass	27340	Pass
27341	Pass	27342	Pass	27343	Pass	27344	Pass
27345	Pass	27346	Pass	27347	Pass	27348	Pass
27349	Pass	27350	Pass	27351	Pass	27352	Pass
27353	Pass	27354	Pass	27355	Pass	27356	Pass
27357	Pass	27358	Pass	27359	Pass	27360	Pass
27361	Pass	27362	Pass	27363	Pass	27364	Pass
27365	Pass	27366	Pass	27367	Pass	27368	Pass
27369	Pass	27370	Pass	27371	Pass	27372	Pass
27373	Pass	27374	Pass	27375	Pass	27376	Pass
27377	Pass	27378	Pass	27379	Pass	27380	Pass
27381	Pass	27382	Pass	27383	Pass	27384	Pass
27385	Pass	27386	Pass	27387	Pass	27388	Pass
27389	Pass	27390	Pass	27391	Pass	27392	Pass
27393	Pass	27394	Pass	27395	Pass	27396	Pass
27397	Pass	27398	Pass	27399	Pass	27400	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory