

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/218/25	Model No.: MARQ-6-50%	Date: 26-06-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 218/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 21701 To 21800 And 21705A	
Month of Manufacturing	: Jun/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 21705A and removed from the Lot/Batch							
21701	Pass	21702	Pass	21703	Pass	21704	Pass
21705	Pass	21706	Pass	21707	Pass	21708	Pass
21709	Pass	21710	Pass	21711	Pass	21712	Pass
21713	Pass	21714	Pass	21715	Pass	21716	Pass
21717	Pass	21718	Pass	21719	Pass	21720	Pass
21721	Pass	21722	Pass	21723	Pass	21724	Pass
21725	Pass	21726	Pass	21727	Pass	21728	Pass
21729	Pass	21730	Pass	21731	Pass	21732	Pass
21733	Pass	21734	Pass	21735	Pass	21736	Pass
21737	Pass	21738	Pass	21739	Pass	21740	Pass
21741	Pass	21742	Pass	21743	Pass	21744	Pass
21745	Pass	21746	Pass	21747	Pass	21748	Pass
21749	Pass	21750	Pass	21751	Pass	21752	Pass
21753	Pass	21754	Pass	21755	Pass	21756	Pass
21757	Pass	21758	Pass	21759	Pass	21760	Pass
21761	Pass	21762	Pass	21763	Pass	21764	Pass
21765	Pass	21766	Pass	21767	Pass	21768	Pass
21769	Pass	21770	Pass	21771	Pass	21772	Pass
21773	Pass	21774	Pass	21775	Pass	21776	Pass
21777	Pass	21778	Pass	21779	Pass	21780	Pass
21781	Pass	21782	Pass	21783	Pass	21784	Pass
21785	Pass	21786	Pass	21787	Pass	21788	Pass
21789	Pass	21790	Pass	21791	Pass	21792	Pass
21793	Pass	21794	Pass	21795	Pass	21796	Pass
21797	Pass	21798	Pass	21799	Pass	21800	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory