

HYDRO PRESSURE TEST

TC No.: HPT/A6/K/HQ/106/25	Model No.: KFKHQ-6	Date: 26-09-2025
Type and Capacity of Extinguisher	: KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr.	
Batch Number	: KFKHQ6 106/25	
Batch Quantity	: 11.00 Nos.	
Serial Numbers	: 01051 To 1060 And 1055A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 1055A and removed from the Lot/Batch							
1051	Pass	1052	Pass	1053	Pass	1054	Pass
1055	Pass	1056	Pass	1057	Pass	1058	Pass
1059	Pass	1060	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory