

## HELIUM LEAK DETECTION TEST

|                                   |                                                               |                  |
|-----------------------------------|---------------------------------------------------------------|------------------|
| TC No.: HLD/A6/K/HQ/088/25        | Model No.: KFKHQ-6                                            | Date: 23-09-2025 |
| Type and Capacity of Extinguisher | : KFKHQ-6-Kanex F Class Kitchen Fire Extinguisher Cap. 6 Ltr. |                  |
| Batch Number                      | : KFKHQ6 088/25                                               |                  |
| Batch Quantity                    | : 10 Nos.                                                     |                  |
| Serial Numbers                    | : 00871 To 880                                                |                  |
| Month of Manufacturing            | : Sep/25                                                      |                  |

| Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result | Sr. Nos. | Result |
|----------|--------|----------|--------|----------|--------|----------|--------|
| 871      | Pass   | 872      | Pass   | 873      | Pass   | 874      | Pass   |
| 875      | Pass   | 876      | Pass   | 877      | Pass   | 878      | Pass   |
| 879      | Pass   | 880      | Pass   |          |        |          |        |

**Remarks:** This is to certify that the above mentioned Fire Extinguishers has been tested on Mass Spectrometer Helium Leak Detector, with test pressure of 1 mbar and desired leak rate of  $1 \times 10^{-6}$  mbar.l/sec and no any cylinders shows leakage beyond this limit.



**Authorized Signatory**