

HYDRO PRESSURE TEST

TC No.: HPT/A6/A50/RQ/193/25	Model No.: KFARQ-6-50%	Date: 12-06-2025
Type and Capacity of Extinguisher	: KFARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: KFARQ50%6 193/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 19201 To 19300 And 19205A	
Month of Manufacturing	: Jun/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 19205A and removed from the Lot/Batch							
19201	Pass	19202	Pass	19203	Pass	19204	Pass
19205	Pass	19206	Pass	19207	Pass	19208	Pass
19209	Pass	19210	Pass	19211	Pass	19212	Pass
19213	Pass	19214	Pass	19215	Pass	19216	Pass
19217	Pass	19218	Pass	19219	Pass	19220	Pass
19221	Pass	19222	Pass	19223	Pass	19224	Pass
19225	Pass	19226	Pass	19227	Pass	19228	Pass
19229	Pass	19230	Pass	19231	Pass	19232	Pass
19233	Pass	19234	Pass	19235	Pass	19236	Pass
19237	Pass	19238	Pass	19239	Pass	19240	Pass
19241	Pass	19242	Pass	19243	Pass	19244	Pass
19245	Pass	19246	Pass	19247	Pass	19248	Pass
19249	Pass	19250	Pass	19251	Pass	19252	Pass
19253	Pass	19254	Pass	19255	Pass	19256	Pass
19257	Pass	19258	Pass	19259	Pass	19260	Pass
19261	Pass	19262	Pass	19263	Pass	19264	Pass
19265	Pass	19266	Pass	19267	Pass	19268	Pass
19269	Pass	19270	Pass	19271	Pass	19272	Pass
19273	Pass	19274	Pass	19275	Pass	19276	Pass
19277	Pass	19278	Pass	19279	Pass	19280	Pass
19281	Pass	19282	Pass	19283	Pass	19284	Pass
19285	Pass	19286	Pass	19287	Pass	19288	Pass
19289	Pass	19290	Pass	19291	Pass	19292	Pass
19293	Pass	19294	Pass	19295	Pass	19296	Pass
19297	Pass	19298	Pass	19299	Pass	19300	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory