

HYDRO PRESSURE TEST

TC No.: HPT/F45/RQ/048/25	Model No.: KFMRQ-45	Date: 02-11-2025
Type and Capacity of Extinguisher	: KFMRQ-45-Kanex M Foam Trolley Mounted Fire Extinguisher Cap. 45 Ltr.	
Batch Number	: KFMRQ45 048/25	
Batch Quantity	: 50.00 Nos.	
Serial Numbers	: 02351 To 2400	
Month of Manufacturing	: Nov/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on Cylinder Sr.No.2005A and which is removed from the batch (41st batch)							
2351	Pass	2352	Pass	2353	Pass	2354	Pass
2355	Pass	2356	Pass	2357	Pass	2358	Pass
2359	Pass	2360	Pass	2361	Pass	2362	Pass
2363	Pass	2364	Pass	2365	Pass	2366	Pass
2367	Pass	2368	Pass	2369	Pass	2370	Pass
2371	Pass	2372	Pass	2373	Pass	2374	Pass
2375	Pass	2376	Pass	2377	Pass	2378	Pass
2379	Pass	2380	Pass	2381	Pass	2382	Pass
2383	Pass	2384	Pass	2385	Pass	2386	Pass
2387	Pass	2388	Pass	2389	Pass	2390	Pass
2391	Pass	2392	Pass	2393	Pass	2394	Pass
2395	Pass	2396	Pass	2397	Pass	2398	Pass
2399	Pass	2400	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 Minute and found satisfactory. No any leakage observed.



Authorized Signatory