

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/282/25	Model No.: MARQ-6-50%	Date: 05-09-2025
Type and Capacity of Extinguisher	: MARQ-6-50%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ50%6 282/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 28101 To 28200 And 28105A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 28105A and removed from the Lot/Batch							
28101	Pass	28102	Pass	28103	Pass	28104	Pass
28105	Pass	28106	Pass	28107	Pass	28108	Pass
28109	Pass	28110	Pass	28111	Pass	28112	Pass
28113	Pass	28114	Pass	28115	Pass	28116	Pass
28117	Pass	28118	Pass	28119	Pass	28120	Pass
28121	Pass	28122	Pass	28123	Pass	28124	Pass
28125	Pass	28126	Pass	28127	Pass	28128	Pass
28129	Pass	28130	Pass	28131	Pass	28132	Pass
28133	Pass	28134	Pass	28135	Pass	28136	Pass
28137	Pass	28138	Pass	28139	Pass	28140	Pass
28141	Pass	28142	Pass	28143	Pass	28144	Pass
28145	Pass	28146	Pass	28147	Pass	28148	Pass
28149	Pass	28150	Pass	28151	Pass	28152	Pass
28153	Pass	28154	Pass	28155	Pass	28156	Pass
28157	Pass	28158	Pass	28159	Pass	28160	Pass
28161	Pass	28162	Pass	28163	Pass	28164	Pass
28165	Pass	28166	Pass	28167	Pass	28168	Pass
28169	Pass	28170	Pass	28171	Pass	28172	Pass
28173	Pass	28174	Pass	28175	Pass	28176	Pass
28177	Pass	28178	Pass	28179	Pass	28180	Pass
28181	Pass	28182	Pass	28183	Pass	28184	Pass
28185	Pass	28186	Pass	28187	Pass	28188	Pass
28189	Pass	28190	Pass	28191	Pass	28192	Pass
28193	Pass	28194	Pass	28195	Pass	28196	Pass
28197	Pass	28198	Pass	28199	Pass	28200	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory