

HYDRO PRESSURE TEST

TC No.: HPT/MA6/A40/RQ/169/25	Model No.: MARQ-6-40%	Date: 08-09-2025
Type and Capacity of Extinguisher	: MARQ-6-40%-Kanex ABC Dry Powder Fire Extinguisher Cap. 6 Kg.	
Batch Number	: MARQ40%6 169/25	
Batch Quantity	: 101.00 Nos.	
Serial Numbers	: 16801 To 16900 And 16805A	
Month of Manufacturing	: Sep/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 16805A and removed from the Lot/Batch							
16801	Pass	16802	Pass	16803	Pass	16804	Pass
16805	Pass	16806	Pass	16807	Pass	16808	Pass
16809	Pass	16810	Pass	16811	Pass	16812	Pass
16813	Pass	16814	Pass	16815	Pass	16816	Pass
16817	Pass	16818	Pass	16819	Pass	16820	Pass
16821	Pass	16822	Pass	16823	Pass	16824	Pass
16825	Pass	16826	Pass	16827	Pass	16828	Pass
16829	Pass	16830	Pass	16831	Pass	16832	Pass
16833	Pass	16834	Pass	16835	Pass	16836	Pass
16837	Pass	16838	Pass	16839	Pass	16840	Pass
16841	Pass	16842	Pass	16843	Pass	16844	Pass
16845	Pass	16846	Pass	16847	Pass	16848	Pass
16849	Pass	16850	Pass	16851	Pass	16852	Pass
16853	Pass	16854	Pass	16855	Pass	16856	Pass
16857	Pass	16858	Pass	16859	Pass	16860	Pass
16861	Pass	16862	Pass	16863	Pass	16864	Pass
16865	Pass	16866	Pass	16867	Pass	16868	Pass
16869	Pass	16870	Pass	16871	Pass	16872	Pass
16873	Pass	16874	Pass	16875	Pass	16876	Pass
16877	Pass	16878	Pass	16879	Pass	16880	Pass
16881	Pass	16882	Pass	16883	Pass	16884	Pass
16885	Pass	16886	Pass	16887	Pass	16888	Pass
16889	Pass	16890	Pass	16891	Pass	16892	Pass
16893	Pass	16894	Pass	16895	Pass	16896	Pass
16897	Pass	16898	Pass	16899	Pass	16900	Pass

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory