

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/130/25

Model No.: KMCRQ-10

Date: 11-09-2025

Type and Capacity of Extinguisher : KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.

Batch Number : KMCRQ10 130/25

Batch Quantity : 10.00 Nos.

Serial Numbers : 01291 To 1300

Month of Manufacturing : Sep/25

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
----------	--------	----------	--------	----------	--------	----------	--------

Burst test conducted on 01291 To 1300 and removed from the Lot/Batch

1291	Pass	1292	Pass	1293	Pass	1294	Pass
1295	Pass	1296	Pass	1297	Pass	1298	Pass
1299	Pass	1300	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.

**Authorized Signatory**