

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/154/25	Model No.: KMCRQ-10	Date: 04-10-2025
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 154/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 01531 To 1540	
Month of Manufacturing	: Oct/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01531 To 1540 and removed from the Lot/Batch							
1531	Pass	1532	Pass	1533	Pass	1534	Pass
1535	Pass	1536	Pass	1537	Pass	1538	Pass
1539	Pass	1540	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory