

HYDRO PRESSURE TEST

TC No.: HPT/MOD10/CA/RQ/155/25	Model No.: KMCRQ-10	Date: 14-10-2025
Type and Capacity of Extinguisher	: KMCRQ-10-Kanex Clean Agent Modular HFC Based Fire Extinguisher Cap. 10 Kg.	
Batch Number	: KMCRQ10 155/25	
Batch Quantity	: 10.00 Nos.	
Serial Numbers	: 01541 To 1550	
Month of Manufacturing	: Oct/25	

Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result	Sr. Nos.	Result
Burst test conducted on 01541 To 1550 and removed from the Lot/Batch							
1541	Pass	1542	Pass	1543	Pass	1544	Pass
1545	Pass	1546	Pass	1547	Pass	1548	Pass
1549	Pass	1550	Pass				

Remarks: This is to certify that the above mentioned Fire Extinguishers are tested for hydraulic pressure of 35 bar for 2.5 minute and found satisfactory. No any leakage observed.



Authorized Signatory